

Motor VFDs rebate incentives and conditions

Revised November 2024

Motor use	Incentive ⁷ (\$/hp)
Fan	\$300
Pump	\$300
Compressor	\$150

Additional requirements

All projects must comply with local codes. All VFD projects require preapproval.

1. Incentives are not available on this page for air handler fan VFDs. See the Cooling rebate incentives for air handler fan VFDs.
2. Incentives are only available for new VFDs installed where none were previously used.
3. Incentives are not available if the VFD is required by ASHRAE 90.1-2016.
4. Incentives are not available for VFDs on unitary cooling equipment when required to achieve the AHRI efficiency rating.
5. Incentives are not available for VFDs on redundant or standby motors.
6. Incentives are not available for VFDs used only as softer starters.
7. Incentives are not available for new pumps and fans with integrated VFDs.
8. Incentives for motors greater than 75 hp must use the custom program.
9. Customer acknowledges that he or she has been made aware of the potential for VFDs to cause harmonic distortion on the facility's electric distribution system and that harmonic distortion can sometimes negatively impact the operation of sensitive electric equipment interconnected with the distribution system.

Continued >

Incentive details and requirements:

- Electric efficiency incentives are available to commercial electric customers of Estes Park Power and Communications, Fort Collins Utilities, Longmont Power & Communications or Loveland Water and Power
- Water efficiency incentives are available to commercial water customers of Fort Collins Utilities, City of Longmont or Loveland Water and Power
- Total incentive amounts over \$10,000 require pre-approval before efficiency upgrades begin
- Total incentives are limited to 100% of a project total upgrade cost
- Efficiency Works Business maximum incentive limits will apply per project, see Program Guide for details
- Funds for incentives are subject to availability. Program requirements including incentive levels and limits are subject to change without advanced notice and may vary by utility.